



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

October 7, 2019
Subject: Culvert Slip Line & Slope
Stabilization
State WIN: 023786.00
Location: **Robbinston**
Amendment No. 1

Dear Sir/Ms.:

Please make the following changes to the Bid Documents:

In the Bid Book:

On pages 46 & 47, in SPECIAL PROVISION - SECTION 509 - CULVERT SLIPLINING, in the section "Basis of Payment", **DELETE** the following:

- c. Widening shoulder for flared end terminal.
- d. Installing guardrail and terminal end.
- e. Design, construction, maintenance and removal of cofferdams and Sediment Basins, including dewatering.
- h. Paving guardrail widening with 4" of HMA.

Make these changes in pen and ink.

The following questions have been received:

Question: Under item 509.202, culvert slip lining basis of payment:
sub paragraph a: does this include the 60"x14' CMP? Can this be Option 111 HDPE?

Response: No, the 60" x 14' CMP will be provided by MaineDOT, to the job site. No, MaineDOT will provide a CMP.

Question: Under item 509.202, culvert slip lining basis of payment:
sub paragraph c, d & I: can a detail be provided for this work showing location & type of end treatment including amount of removing & resetting of guardrail?

Response: Sub paragraph c & d, see above changes. Item (i), under the 509.202- Removing and Resetting Existing Guardrail, it is up to the Contractor to decide if they want to take down the guardrail to do the work.

Question: Sub paragraph h: will a paving specification be added for the guardrail widening and will a waiver for the seasonal time limitation be granted.


Response: See above changes. Due to the lateness in the season, MaineDOT will repair guardrail shoulder area in the Spring of 2020 at their expense.

Question: Subparagraph e: says cofferdams incidental to slip lining but there are pay items for them. Will they be paid for under the cofferdam items?

Response: See above changes. Cofferdams will be paid for under Item 511.07.

Consider these changes and information prior to submitting your bid on **October 16, 2019**.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer